





## شركة الكرحي التجارة والمقاولات Al Kurdi Trading & Contracting Co.

Contract No. (60/04/35/44) PROJECT NAME: Al Amal Hospital.

LOCATION:

Riyadh SAUDI ARABIA PAGE

			SAUDI ARABIA 01 OF 01
DOCUMENT SUBMITTAL		MECHANICAL PUMP SETS	S.
Ref. No: AKTC_003		Submittal No: 003	and the second control of the second section of the second second of the second of the second
Date : 30 - 01 - 2019.		■ New Submittal	Re Submittal
DISCIPLINE: E PUMP SETS		P SETS	MECH PIPES
		ENCLOSURES	
▼ Test Data.  ✓ Material Substitution  ✓	omittal.	☑ Catalogue.  ☑ TEST Report.	Mfg. Cert. Specifications.

Manufacturer	Country of Original Certificate		CAPACITY	Description of Material	No. of Copy	Action Code
SPP PUMPS	USA UL/FM	2000	ELECTRIC PUMP	01	·A	
		UL / FM	GPM/145 PSI/10 BAR	DIESEL PUMP	01	0
				JOCKEY PUMP	01	A
Speci	fication & BOO	3	c: /	As per attached	Locat	lon/ Use

Action Codes (A)Approved

(B) Approved as noted

(C) Revised & Re-submit

(D) Rejected





Address: PO Box 110A. Al Ahsa. Kingdom of Saudi Arabia

Contractor: Saudi Aircon

TO: King Faisal Specialist Hospital & Research Centre			Form No.: SBMT			
FROM: Saudi Aircon		REF.# 2 Contract # C/0009/37 End of Contract				
PROJECT TITLE: Replacement and Upgrading of HVAC Equipment in KFSH-East Building, HITA Building and Outpatient Building Project		Trade Arch'tl I.D Str/Civil þ Elect'rl.þ Mech Safety Planner QS				
	of Submittal	Submittal No.	::SBMT-C/0009/37-0177 Date: 01-Dec-2018			
Drawing b Materials Samples Catalogue Mock-up Others		New Submitta	al: " Re-Submittal: þ			
	ECT: Fire pump Set					
ITEM No.	DESCRIPTION OF ITEM	TRADE	REVIEWER'S REMARKS	ACTION CODE		
1	Al-mousa EST , Two SPP (USA) Electrical Fire Pumps	Mech	Mechanical Comments (SPP – Al Mousa Est.) - Proposed UL-listed and FM-approved fire pump model is acceptable for Mechanical Section however UL-listing and FM-Approval of pump MOTOR/DRIVER and pump CONTROLLER shall be verified and approved by the FPMD Electrical Engineer; Proposed jockey pump is also acceptable for Mechanical Section however this shall be for review and approval by the FPMD Electrical Engr. for its Electrical Specs; ALL Mechanical System components shall also be UL-listed and FM-Approved; Base plate shall be part of the scope of the supplier (shall be factory-installed and not field-installed); ALL ITEMS NOTED AS "NOT IN THE SCOPE" or "N/A" BY THE SUPPLIER BUT REQUIRED FOR THE FULL FUNCTIONALITY OF THE SYSTEM, REQUIRED FOR CIVIL DEFENCE COMPLIANCE AND REQUIRED CONTRACTUALLY SHALL BE THE RESPONSIBILITY AND SHALL BE FINANCIALLY-SHOULDERED BY THE MAIN	В		

Page 1 of 6 KFSH-PRSD





Address: PO Box 110A: Al Ahsa: Kingdom of Saudi Arabia

Contractor: Saudi Aircon

		l .		
			CONTRACTOR (NO ADDED COST TO KFSH&RC).  A/C:B  50HP, 3P, 400V rating for fire pumps is acceptable.	
		Elec	However, please confirm to FPMD Mechanical Engineer the rating of fire pump. Remote alarms panel shall interface to the existing fire alarm system and BMS with Nema-4 enclosure. One (1) Control panel is require for both 1-duty and 1-stand by fire pumps with built-in automatic transfer. Jockey pump and fire pumps controller enclosure shall be NEMA 4. Site training is require on site. Site Acceptance test to be performed by the system supplier to be witness by the end user department. Submit factory acceptance test and warranty shall be in accordance to the project contract. Comply with the project specification and contract documents. Valves and gauges shall be connected to BMS. A/C:B	В
2	Al-mousa EST Two Pentair Aurora (USA) Electrical	Mech	Mechanical Comments (Pentair Aurora – Al Mousa Est.) - Proposed UL-listed and FM-approved fire pump model is acceptable for Mechanical Section however UL-listing and FM-Approval of pump MOTOR/DRIVER and pump CONTROLLER shall be verified and approved by the FPMD Electrical Engineer; Proposed jockey pump is also acceptable for Mechanical Section however this shall be for review and approval by the FPMD Electrical Engr. for its Electrical Specs; ALL Mechanical System components shall also be UL-listed and FM-Approved; Warranty not covered by the supplier shall be covered by the main contractor (need official guarantee letter to augment this	В

Submittal of Documents or Materials for Approval on

Page 2 of 6

KFSH-PRSD





Address: PO Box ١٦٥٨، Al Ahsa، Kingdom of Saudi Arabia

Contractor: Saudi Aircon

	submittal from main contractor); ALL ITEMS NOTED AS "NOT IN THE SCOPE" or "N/A" BY THE SUPPLIER BUT REQUIRED FOR THE FULL FUNCTIONALITY OF THE SYSTEM, REQUIRED FOR CIVIL DEFENCE COMPLIANCE AND REQUIRED CONTRACTUALLY SHALL BE THE RESPONSIBILITY AND SHALL BE FINANCIALLY-SHOULDERED BY THE MAIN CONTRACTOR (NO ADDED COST TO KFSH&RC). A/C:B	
Elec	Remote alarms can be interface to the existing fire alarm system and BMS with Nema-4 enclosure. One (1) Control panel is require for both 1-duty and 1-stand by fire pumps with built-in automatic transfer. Site training is require on site. Site Acceptance test to be performed by the system supplier to be witness by the end user department. Submit factory acceptance test and warranty shall be in accordance to the project contract. Comply with the project specification and contract documents. A/C:B	В
		Page 2 of 4

Submittal of Documents or Materials for Approval on

Page 3 of 6 KFSH-PRSD





Contractor : Saudi Aircon

ACTION CODE LEGEND.					
ACTION CODE LEGEND:	D. Not approved (Work shall not proceed)				
A. Approved as submitted					
B. Approved as noted. (Work may proceed, resubmission					
C. Approved as noted. (Work may proceed, resubmission					
REVIEWED BY: ( PRSD Staff )					
/	Neil Reguine/02-Dec-18 11:10 AM	Abdullah Bin Enaiq			
Architect/Date	Mechanical Engr. /Date	Project Manager			
/	1				
Planner/Scheduler /Date	QS/Date	as noted			
/	Jessie Laya/03-Dec-18 08:29 AM				
Interior/Date	Electrical Engr. / Date	PM Comment			
7	7	03-Dec-2018			
Civil/Structural Engr. / Date	Safety Officer / Date	Date Returned			